

LOCATION 924 1/2 N. Highland St. CITY Gastonia
BETWEEN Davidson STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	40'	3-31-00	Retired 1" Bare	
MAIN TO PROP. LINE	3/4"	P	10'		Purged & Foamed	
PROP. LINE TO BLDG.	3/4"	P	30'		3-31-00	

ENTERS: Same BRANCHED INTO

TAP SIZE: 1/4" PRESSURE 60 PSI INCHES W.C. LOCATION 11' East of N.

Highland St & 749' South of W. Davidson


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RTS

MAIN SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH 2 FT 6 IN. LOCATION 11' East of N. Highland St.

"A" P/S READING 1.0 (main) TOTAL ANODES 1# 17 L.R. #

REMARKS: Retired & Renewed Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P. Riser
P/S Pipeline Lead - White Existing Main	E	