

LOCATION 925 & 929 N. Highland St. CITY DAVENPORT
BETWEEN DAVIDSON ST. STREET & DEAD END STREET

	SIZE	TYPE	925 LENGTH	929	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	Plastic	85'	62'	8-1-02	85' 3/4 C/W	ON 925
MAIN TO PROP LINE	5/8"	Plastic	32'	42'		Retired 62' 3/4 C/W	
PROP LINE TO BLDG	5/8"	Plastic	53'	20'		ON 929	


ENTERS 925 BRANCHED INTO 929
TAP SIZE 3/8" PRESSURE 60 PSI INCHES W C LOCATION 853' N of C of Davidson St.

PRESSURE TEST @ 100 PSI FOR 44 HRS BY RL
MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1963

DEPTH 3 FT 6 IN LOCATION 12' E of C of N. Highland

"A" P/S READING 1.1 TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Rose's Plastic
P/S Pipeline Lead - White Existing Main	E	