

LOCATION 931 & 933 N. Highland

CITY _____

BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>		<u>Bonded Eff. Insulated</u>		<u>Muller</u>
MAIN TO PROP. LINE				<u>Tees</u>	<u>3-30.00</u>	<u>E. Perry</u>
PROP. LINE TO BLDG.						


ENTERS: 933BRANCHED INTO: 931

TAP SIZE: _____ PRESSURE _____ PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ _____ PSI FOR _____ HRS. BY _____

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1961DEPTH: 2 FT. 0 IN. LOCATION _____"A" P/S READING .954 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: _____

	Test Station			ENG. DEPT. USE ONLY # <u>931</u> # <u>933</u>
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S Riser</u>	<u>.950</u>	
	P/S Pipeline Lead - White Existing Main	<u>E Riser</u>	<u>.934</u>	