

LOCATION 1323 N. Highland ST CITY GASTONIA
 BETWEEN Boulevard Dr. STREET & Cameras Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	75'	8-2-01		
MAIN TO PROP LINE	3/4"	P	35'			
PROP LINE TO BLDG	3/4"	P	40'			

ENTERS 1323 BRANCHED INTO
 TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 88' W. of center of N Highland St

PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1963

DEPTH 2' ET 0 IN LOCATION 18' N. of center of Boulevard St

"A" P/S READING TOTAL ANODES 1# 0 17# 0 LR # 18880

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

