

LOCATION 3004 High Ridge Ct CITY Castroville
 BETWEEN Daffodil Ct STREET & Colony Woods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	134'	7-12-01		
MAIN TO PROP LINE	3/4"	P	40'	"		
PROP LINE TO BLDG	3/4"	P	94'	"		

ENTERS 3004 BRANCHED INTO Ø
 TAP SIZE 1/2" PRESSURE 60 PSI INCHES W C LOCATION 292' East


PRESSURE TEST @ 100 PSI FOR 14 HRS BY D. Woody
center of Hoffman Rd.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3' 0" FT IN LOCATION 17' south of center of High Ridge

"A" P/S READING N/A TOTAL ANODES 1# A 17# Ø LR # C0003362

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>rise</u>