

LOCATION 3012 High Ridge Ct CITY Atlanta
BETWEEN Hoffman STREET A STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>94'</u>	<u>9-1-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>89'</u>			

ENTERS: 3012 BRANCHED INTO 0
TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY EB

MAIN SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # _____

REMARKS. _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	0.125V
P/S Pipeline Lead White Existing Main	E	