

LOCATION 3012 High Ridge Ct. CITY Castonia

BETWEEN Holtzman Rd. STREET & Cal-de-Site STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>131'</u>	<u>2-26-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>91'</u>			

ENTERS 3012 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 439' E. of center of Holtzman Rd.


PRESSURE TEST @ 100 PSI FOR 14 HRS BY S. G.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC / YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 17' S. of center of High Ridge Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 133123

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	