

LOCATION 3053 HIGH RIDGE CT. CITY GASTONIA
BETWEEN HOFFMAN STREET & Cul de sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>97'</u>	<u>11.27.01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>92'</u>			


ENTERS 3053 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION N. side of 3053

PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY GK
MAIN-SIZE 2 C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 1998

DEPTH _____ FT _____ IN _____ LOCATION E side of cul-de-sac

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	