

LOCATION S13 Hillcrest AveCITY GastoniaBETWEEN S. York RdSTREET & Florida St

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>12'</u>	<u>Tied over</u>	<u>86' of existing</u>	<u>3/4 plastic</u>
MAIN TO PROP. LINE				<u>Service to</u>	<u>new 2" plastic main</u>	
PROP. LINE TO BLDG.				<u>1-29-98</u>		

ENTERS: S13

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SEMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997DEPTH: 6 FT. 0 IN. LOCATION \_\_\_\_\_"A" P/S READING PL TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

MAIN Directional Bore under Rock \*Note 6' Deep

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY