

LOCATION 604 Hillcrest Ave CITY Gastonia  
BETWEEN Florida STREET & Linebarger STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>plast.</u>	<u>141'</u>			<u>1-26-98</u>
MAIN TO PROP. LINE	<u>1</u>	<u>1</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>1</u>	<u>1</u>	<u>95</u>			

ENTERS: 604 BRANCHED INTO: -  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1991  
DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING Plaster TOTAL ANODES T# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>PL.</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY