


LOCATION 610 W. Hillcrest AveCITY GastoniaBETWEEN FloridaSTREET & Linberga St

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>112'</u>		<u>1-</u>	<u>24-98</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>67'</u>			

ENTERS: 610BRANCHED INTO: -TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SEMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED _____DEPTH: 3 FT. 0 IN. LOCATION _____"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	