

LOCATION 610 HILLCREST AVE APT A CITY Groton
BETWEEN JACKSON STREET & Florida STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>57</u>	<u>8-9-00</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>8</u>			
PROP LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>57</u>			

ENTERS: 610 BRANCHED INTO: APT A
TAP SIZE: 3/4 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 23' E. of coop


PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY JP Hillcrest

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 22 1998

DEPTH: 1 FT 10 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ I.R. # _____

REMARKS.

	Test Station	
	Reading & Location	Volts
	P/S Pipeline Lead - Red New Service	<u>OR</u>
	P/S Pipeline Lead - White Existing Main	<u>P</u>