

LOCATION 619 Hillcrest Ave CITY Conestoga
BETWEEN Linsberger STREET & Jackson Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>2'</u>			
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

Tied on 44' of EXT 3/4
plastic with 2' of New 3/4 plastic
- 1-22-98


ENTERS: 619 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE: 60 PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 PSI FOR 164 HRS. BY EP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY