

LOCATION 619 W. Hill Crest Ave. CITY GASTONIA
BETWEEN JACKSON Rd. STREET & LINE BERGER Ave. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>60'</u>	<u>9-2-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>13'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>47'</u>			

ENTERS: 619 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 145' S of E of Jackson Rd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL N COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1949?
DEPTH: 2' FT. 0 IN. LOCATION 7' W of E of Hill Crest Ave.

"A" P/S READING .50 TOTAL ANODES 1# _____ 17# 1 L.R. # 571461

REMARKS: MAIN to be renewed on Bare Main Renewal shortly.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY