


LOCATION 1005 Hillside Dr. CITY EastBETWEEN Forest Hill STREET & Tenth Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>3' T/OVER</u>			<u>4-10-92</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>				
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>				

ENTERS: SAMP

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 118' From (C) OFHillsidePRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ADHMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1982DEPTH: 3 FT. 0 IN. LOCATION West side of Hillside"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY