


LOCATION 1820 Hill Top CircleCITY CASTONIABETWEEN Hunt Ave.STREET & 1825 Hill Top Circle

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>65'</u>	<u>8-2-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>60'</u>			

ENTERS: 1820BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 160' S of C of Hunt Ave.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By ALMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1987DEPTH: 3 Ft. 0 In. LOCATION 13' E of C of Hill Top Circle"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY