

LOCATION 1863 Hilltop CircleCITY GastoniaBETWEEN HilltopSTREET & Hilltop

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	130'	3-22-94		
MAIN TO PROP. LINE	3/4	P	35			
PROP. LINE TO BLDG.	3/4	P	95'			

ENTERS: 1863BRANCHED INTO: 0

TAP SIZE: <u>1/2</u>	PRESSURE <u>60</u> P.S.I.	INCHES W.C.	LOCATION <u>E side of 1863</u>
----------------------	---------------------------	-------------	--------------------------------


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC

MAIN-SIZE <u>2"</u>	C.I. <u> </u>	BARE STEEL <u> </u>	COATED STEEL <u> </u>	PLASTIC <u>✓</u>	YEAR INSTALLED <u>1993</u>
---------------------	------------------	------------------------	--------------------------	------------------	----------------------------

DEPTH: <u>3</u> Ft.	In.	LOCATION <u>10' N of C of Hilltop</u>
---------------------	-----	---------------------------------------

"A" P/S READING <u>Plastic</u>	TOTAL ANODES 1* <u>-</u> 17* <u>-</u>	L.R. # <u>110573</u>
--------------------------------	---------------------------------------	----------------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY