

LOCATION 1897 Hilltop Circle CITY Gastonia
BETWEEN Hunt Ave. STREET & Hunt Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>80</u>	<u>11-3-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>30</u>	<u>"</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>50</u>	<u>"</u>		


ENTERS: 1897 Hilltop Circle BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 211' East of
Center of Hunt Ave.

PRESSURE TEST: @ 100 lb. PSI FOR 1/4 HRS. BY [Signature]
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 FT. 0 IN. LOCATION 12' North of Center
of Hilltop Circle

"A" P/S READING Plastic TOTAL ANODES 1# 0 17# 0 L.R. # 756 307

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY