

LOCATION 1281 Hoffman Rd. CITY GASTONIA
BETWEEN Ivy Creek STREET & Robinwood Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>CW</u>	<u>18'</u>	<u>8-5-94</u>	<u>Lowered</u>	<u>Existing 3/4</u>
MAIN TO PROP. LINE					<u>CW Service.</u>	
PROP. LINE TO BLDG.						

ENTERS: 1281 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE _____ C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____

DEPTH: _____ Ft. _____ In. LOCATION _____

"A" P/S READING 85 TOTAL ANODES 1# 17# L.R. # _____

REMARKS: Lowered Existing 3/4 Service For Grading Purpose + Stump Removal.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY