

LOCATION 320 Hollow Pine Ct. CITY GASTONIA
BETWEEN Creekridge Dr. STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	91'	4-4-00		
MAIN TO PROP. LINE	3/4"	P	20'			
PROP. LINE TO BLDG.	3/4"	P	71'			

ENTERS: 320 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 230' SW. of center of Creekridge Dr.

PRESSURE TEST @ 100 PSI FOR 1 HRS BY SK
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
DEPTH 3 FT 0 IN LOCATION 21' SE. of center of Hollow Pine Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 283350

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

