

LOCATION 805 Holy Trinity CITY East.

BETWEEN Garrison Blvd STREET & Tenth St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>80'</u>		<u>5-</u>	<u>9-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>56'</u>			
PROP. LINE TO BLDG.	<u>"</u>		<u>24'</u>			

ENTERS: same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 331' from (A) of

Garrison Blvd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ALH

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION West side of S Chester St.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY