

LOCATION 713 Honeywood LN. CITY SEAFOUR  
BETWEEN \_\_\_\_\_ STREET & \_\_\_\_\_ STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	105'	7-18-97		
MAIN TO PROP. LINE	3/4"	P	35'			
PROP. LINE TO BLDG.	3/4"	P	70'			

ENTERS: 713 BRANCHED INTO: \_\_\_\_\_  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 34' NE of center of  
W. Willowbrook CT

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Bullard  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1964  
DEPTH: 4 FT. 0 IN. LOCATION 16' SE of center of Honeywood LN.

"A" P/S READING 0.5 TOTAL ANODES 1# 0 17# 1 L.R. # 459265

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY