

LOCATION 1219 Hooper Ave CITY Cos Linn  
 BETWEEN Vance STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>CW</u>	<u>26'</u>		<u>8-22-85</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1219 BRANCHED INTO: 1221  
 TAP SIZE: 3/4 IN. PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST: @ \_\_\_\_\_ psi For \_\_\_\_\_ Hrs. By \_\_\_\_\_

MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1964

DEPTH: 2 Ft. 0 In. LOCATION \_\_\_\_\_

"A" P/S READING 1.0 TOTAL ANODES 1# 17# L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Refused</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY