

LOCATION 2808 Hovis Ct. CITY GASTONIA  
BETWEEN Southampton STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>150'</u>	<u>2-17-97</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>105'</u>			


ENTERS: 2808 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION 20' S. of Cap  
Hovis Ct.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP  
MAIN SIZE: 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1981

DEPTH: 3 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING P. 70 TOTAL ANODES 1# \_\_\_\_\_ 17# 1 L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY