

LOCATION 3206 Apt C Howe Dairy CITY GASTONIA
BETWEEN NEAL Hawkins STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>367</u>	<u>9-20-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>322'</u>			

ENTERS: 3206

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 12' W OF


HOWE DAIRY
PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M. Parker

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL 2 PLASTIC _____ YEAR INSTALLED 1980

DEPTH: 3 FT. 0 IN. LOCATION 501' south of Neal Hawkins

"A" P/S READING 1.2 TOTAL ANODES 1# _____ 17# _____ I.R. # 510419

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>CW RISEK</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY