

LOCATION 328 Hudson Blvd CITY Gastonia  
BETWEEN Clyde STREET & S. York Rd STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>274'</u>	<u>1-14-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>				
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>				

ENTERS: 328 Hudson Blvd BRANCHED INTO: ←  
TAP SIZE: 3/4 PRESSURE 60 P.S.I. INCHES W.C. LOCATION

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Orme  
MAIN-SIZE 4" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1997  
DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING P TOTAL ANODES 1\* — 17\* — L.R. # 022302

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY