

LOCATION 1261 Hudson Av

CITY Gastown

BETWEEN Golf Course Dr.

STREET & Hudson Av.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE:

PRESSURE _____ P.S.I. _____ INCHES W.C.

LOCATION


PRESSURE TEST: @ _____ psi For _____ Hrs. By _____

MAIN-SIZE _____ C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____

DEPTH: _____ Ft. _____ In. LOCATION

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	SR	1.200
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY