

LOCATION 310 Nuffman St CITY GASTON, N.C.
 BETWEEN Cable STREET & Birchfield Ln STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	PLASTIC	94'	5/5/99		
MAIN TO PROP. LINE	3/4"		28'			
PROP. LINE TO BLDG	3/4"		66'			

ENTERS: 310 BRANCHED INTO
 TAP SIZE 3/8" PRESSURE 60 PSI INCHES W.C. LOCATION W. side of 310


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D.T.

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1967

DEPTH 2 FT 6 IN LOCATION South side of Nuffman St

A P/S READING 1.40 TOTAL ANODES 1# 0 17# 0 I.R. # 402053

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	