

LOCATION 117 Huffstetler Rd. CITY Castonia

BETWEEN Pinewood Cr STREET & S. New Hope Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>105'</u>	<u>6-30-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>85'</u>			

ENTERS: 117 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 262' NE of center of

Pinewood Cr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetler

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 FT. 0 IN. LOCATION 12' N. of center of Huffstetler Rd

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 465627

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		