

LOCATION 123 Huffstetter Rd. CITY GASTONIA

BETWEEN Pinewood STREET & Si New Hope STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>78'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>	<u>7-26-99</u>		
PROP LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>68'</u>			

ENTERS. 123 BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST @ 100 PSI FOR 114 BY EP

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH 3 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# 17 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	