

LOCATION 232 Huffstetter Rd. CITY GASTAVIA

BETWEEN Pinewood Cr STREET & Forest Cr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>111'</u>	<u>11-5-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>76'</u>			

ENTERS: 252 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 789' Sw. of center of Pinewood Cr


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffstetter

MAIN-SIZE 4' C.I.      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1989

DEPTH: 3 Ft. 0 In. LOCATION 14' Nw. of center of Huffstetter Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 625715

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY