

LOCATION 1613 Hunsinger ave CITY Gastonia

BETWEEN Baker Blvd STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Low steel</u>	<u>50</u>		<u>9-26-96</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>Low steel</u>				
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Low steel</u>				

ENTERS: 1613 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION west side of house


PRESSURE TEST: @ \_\_\_\_\_ psi For \_\_\_\_\_ Hrs. By \_\_\_\_\_

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1961

DEPTH: 2 Ft. 6 In. LOCATION South of center of Hunsinger

"A" P/S READING 1.0 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY