

LOCATION 3305 Huntington Wood Ct CITY Gastonia  
BETWEEN Forest Creek Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	105'	3-26-02		
MAIN TO PROP. LINE	5/8"	P	45'			
PROP. LINE TO BLDG	5/8"	P	60'			

ENTERS 3305 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W/C LOCATION 50' NW. 1/4 part  
of Huntington Wood Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SEA

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 2001

DEPTH 3 FT 0 IN LOCATION 14' N. of center of Forest Creek Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 119427

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	