

LOCATION 3313 Huntingwood Ct CITY ASTONIA  
 BETWEEN \_\_\_\_\_ STREET & \_\_\_\_\_ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>138'</u>	<u>7-26-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>Plastic</u>	<u>48'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>90'</u>			

ENTERS 3313 BRANCHED INTO 0  
 TAP SIZE 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES WC LOCATION 98' S of C of Forest Creek Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2 1/2 C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 6 IN LOCATION 21' E of C of Huntingwood Ct.

"A" P/S READING Plastic N/A TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

COPY