

LOCATION 3361 Huntington Wood Ct CITY Gastonia
BETWEEN _____ STREET - & _____ STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>89'</u>	<u>12.20.01</u>	<u>12.20.01</u>	
MAIN TO PROP LINE	<u>2"</u>	<u>"</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>2"</u>	<u>"</u>	<u>49'</u>			

ENTERS 3361 BRANCHED INTO _____
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION N side of 3361

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY GR
MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 2001
DEPTH 3 FT _____ IN LOCATION W side of Huntington Wood

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	