

LOCATION 3425 HUNTINGTON WOOD CT CITY GASTONIA  
BETWEEN \_\_\_\_\_ STREET & \_\_\_\_\_ STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>111</u>	<u>12-20-01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>40</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>7</u>			

ENTERS 3425 BRANCHED INTO \_\_\_\_\_  
TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION S. side of 3425

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY GK  
MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC / YEAR INSTALLED 2001  
DEPTH 0 FT IN LOCATION E. side of Huntington Wood Ct

"A" P/S READING N/A TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	