

LOCATION 3329 Hunting Wood Ct. CITY Gastonia
 BETWEEN Strong Box Lnr. STREET & Forest Creek Ct. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	26'	7-02-01		
MAIN TO PROP. LINE	3/4"	P	10'	"		
PROP. LINE TO BLDG	3/4"	P	16'	"		

ENTERS 3329 BRANCHED INTO 3337
 TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 265' South

PRESSURE TEST @ 160 PSI FOR 1/4 HRS BY D. Woody
 MAIN-SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2001
 DEPTH 1' FT 18" IN LOCATION 89' West of center of Hunting Wood Ct.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 I.R. # 00483633

REMARKS New 3/4" plastic service.
Power Line (cut) was not located) ticket good



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	rise