

LOCATION 3337 Hunting Wood ct CITY Gastonia  
BETWEEN Forest Creek ct. STREET & Strong Box Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>128'</u>	<u>6-18-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>88'</u>	<u>"</u>		

ENTERS 3337 BRANCHED INTO Ø  
TAP SIZE 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 268' south


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY Ø center of Forest Creek ct.  
D. Woody

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0" IN LOCATION 17' East of center of Hunting Wood ct

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 00483481

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>