

LOCATION 3368 Hunting Wood CT CITY Gastonia
BETWEEN Forest Creek CT STREET & Cuba de Sae STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>59'</u>	<u>7-2-04</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>54'</u>			

ENTERS 3368 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 607' S. of center of Forest Creek CT


PRESSURE TEST @ 100 PSI FOR 14 HRS BY S. A.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 18' E of center of Hunting Wood CT

"A" P/S READING P TOTAL ANODES 10 17# 0 LR # A0539415

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	