

LOCATION 3385 Huntingwood Ct. CITY Gaston, N.C.

BETWEEN Forest Creek Ct. STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>104'</u>	<u>8-20-01</u>		
MAIN TO PROP LINE	<u>3/8"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>59'</u>			

ENTERS 3345 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 690 S. of center of Forest Creek Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 20' E. of center of Huntingwood Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 622258

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	