

LOCATION 3409 Hunting Wood Ct. CITY GASTON, N.C.
BETWEEN Forest Creek Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>111'</u>	<u>5-14-01</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>66'</u>			

ENTERS 3409 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 858' SE. of center of Forest Creek Ct.


PRESSURE TEST @ 60 PSI FOR 14 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 19' NE. of center of Hunting Wood Ct.

"A" P/S READING 7 TOTAL ANODES 1# 0 17# 0 LR # 340185

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	