

LOCATION 3433 Huntingwood Ct CITY Castania
BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>15'</u>	<u>8-20-01</u>		
MAIN TO PROP LINE						
PROP LINE TO BLDG						


ENTERS 3433 BRANCHED INTO _____
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 130' W. of Center of Huntingwood Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. H.
MAIN-SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2001

DEPTH 2 FT 0 IN LOCATION 60' N. of center of Rd. de - Sec

"A" P/S READING P TOTAL ANODES 1# 0 17# 2 L.R. # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	