

LOCATION 3441 Humming Wood CT CITY Canton
BETWEEN Forest Creek CT STREET & Cut-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	68'	7-3-01		
MAIN TO PROP LINE	3/4"	P	5'			
PROP LINE TO BLDG	3/4"	P	63'			

ENTERS 3441 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 11' W. of center of
Cut-de-Sac


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.G.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 44' S. of center of Cut-de-Sac

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 483702

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	