

LOCATION 640 Huntsman Ct. CITY Canton
BETWEEN Union Rd. STREET & Cut-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>150'</u>	<u>8-25-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>60'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>90</u>			


ENTERS: 640 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 440' W. of center of Union Rd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstiller
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1988

DEPTH: 3 FT. 0 IN. LOCATION 27' S. of center of Huntsman Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 540355

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY