

LOCATION #1180 & 1172 Huntmoor Dr. CITY Gastonia
 BETWEEN Brandvane STREET & Stonebrook STREET

	SIZE	TYPE	1180 LENGTH 1172	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	37' 11" 22'		#1180 105' of 3/4" CW	7-11-85
MAIN TO PROP. LINE	3/4	P	70'	#1172	Tied over 54' of Ext 3/4" CW	
PROP. LINE TO BLDG.	3/4	P	67'		to New 3/4" plastic in #1180	

ENTERS: 1180 BRANCHED INTO: 1172

TAP SIZE: 3/4 PRESSURE 100 P.S.I. INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By [Signature]

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1969

DEPTH: 3 Ft. 6 In. LOCATION

"A" P/S READING 8 TOTAL ANODES 1# 17# 2 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	#1180 - S	Plastic
P/S Pipeline Lead - White Existing Main	#1172 - E	Riser 1.3'

ENG. DEPT. USE ONLY