

LOCATION: 1301-A Huntsmoor Dr. CITY Castania
 BETWEEN 3. New Hope Rd. STREET & Stoneybrook Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
Serv. MAIN TO BLDG	3/4"	P	63'	2-1-00		
Serv. MAIN TO PROP LINE	3/4"	P	0	Split service off of 1301		
PROP. LINE TO BLDG	3/4"	P	0	Huntsmoor Dr.		

ENTERS: 1301 BRANCHED INTO 1301-A

TAP SIZE: 3/4" PRESSURE 60# PSI _____ INCHES W.C. LOCATION 120' South of Huntsmoor Dr & 214' west of Stoneybrook Ave.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY BB

Serv. ~~MAIN~~ SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1999

DEPTH: 2 FT 0 IN LOCATION 120' South of Huntsmoor Dr.

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Installed new plastic service. Came off of 3/4" plastic stub.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	PRISEE
P/S Pipeline Lead - White Existing Main	E	