

LOCATION 2624 Independence wayCITY GastoniaBETWEEN Londonberry Dr.

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>31'</u>	<u>11-17-94</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>21'</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE:


PRESSURE

P.S.I.

INCHES W.C.

LOCATION 110' N. of C ofIndependence wayPRESSURE TEST: @ 100 psi For 1/4 Hrs. By SPMAIN - SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED DEPTH: 1 Ft. 6 In.

LOCATION

"A" P/S READING PTOTAL ANODES 1# 17# L.R. # REMARKS: tested Repl

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY