

LOCATION 1210 INDUSTRIAL AVE. CITY GASTONIA

BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH		INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>39'</u>	<u>60'</u>		<u>6-9-97</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>0</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>39'</u>	<u>58'</u>			

ENTERS: SAME BRANCHED INTO: _____

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION EAST SIDE OF 1210

NORTH SIDE OF 1210


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY B.T.

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 97

DEPTH: 4 FT IN LOCATION WEST SIDE OF INDUSTRIAL AVE.

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY