

LOCATION 1212 Industrial Ave. CITY Gastonia
BETWEEN HANCOCK ST. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>Tie-over</u>			
MAIN TO PROP. LINE			<u>to New 4"</u>	<u>10-28-97</u>		
PROP. LINE TO BLDG.			<u>Plastic</u>			

ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI INCHES W C LOCATION 16' N of Industrial Ave

571' West of Hancock St


PRESSURE TEST: @ 100# PSI FOR 1/4 HRS BY B.B

MAIN-SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 4 FT 0 IN LOCATION 16' North of Industrial Ave.

"A" P/S READING Plastic TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS: Tied over Existing 3/4" plastic service to New 4" plastic Main

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		