

LOCATION 1262 Industrial Ave. CITY GASTONIA
BETWEEN Hancock St. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	56'	10-20-98	Retired	147' Existing 3/4
MAIN TO PROP. LINE	3/4	Plastic	6'		CW Service Pipe	5
PROP. LINE TO BLDG.	3/4	Plastic	50'		Pressers in line	

ENTERS: 1262 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 1387' N of C of Hancock St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY: RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1998

DEPTH: 3 FT 0 IN. LOCATION 12' W of C of Industrial Ave.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 0212 9489

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser
P/S Pipeline Lead - White Existing Main	E	Plastic

ENG. DEPT. USE ONLY